



AUTHORIZATION TO MARK

This authorizes the application of the Certification Marks shown below to the Product Covered (also to the multiple listee model identified on the correlation page of the Listing Report where applicable) when made in accordance with the Description and under the conditions set forth in the Certification Agreement and Listing Report:

Applicant: RF-MTL Electronics inc.
 7103, route Transcanadienne, suite 208
 Saint-Laurent, Qc Canada H4T 1A2

Contact: Name: Eugen Budileanu Phone: (514) 332-9998

Manufacturer: (Same as Applicant)

Party Authorized To Apply Mark: (Same as Manufacturer)

Report Issuing Office: Lachine, Montreal

Report No.: 3034789

Product Covered: Industrial control panels, for dry or wet locations, floor or wall mounted, up to 600 V, 50/60 Hz, single or three-phase, 100 hp, 200 A max

Description: Special control assemblies may include main switch, contactors, overload relays, circuit breakers, fuseholders, transformers, plc, wiring terminals, relays, timers, variable drives, pilot lights and pushbutton switches. They are for installation and use in non-hazardous dry or wet locations in accordance with the Canadian Electrical Code.

Standard(s): CSA C22.2 no. 14-95

This document is the property of Intertek Testing Services and is not transferable. Only the Applicant may reproduce this document. The certification mark(s) may be applied only at the above noted location of the Party Authorized To Apply Mark.



Authorized by: William T. Starr Date: JUNE 3, 2003
 William T. Starr, Certification Manager *Jim*

Control Number: 3036944

Intertek Testing Services NA Inc.
 165 Main Street, Cortland, NY 13045-2995
 Telephone 800-345-3851 or 607-753-6711 Fax 607-756-6699